



### WATER REQUIREMENT

-AT FIELD ELEVATION  
-WITHIN 100' OF FIELD  
-DOWNSTREAM OF  
-BACKFLOW IS 103 GPM @  
53 PSI

### IRRIGATION LEGEND

- PRODUCT DESCRIPTION**
- HUNTER I-35-06-SS-XX NOZZLE AS SHOWN
  - HUNTER I-35-06-SS-XX NOZZLE AS SHOWN
- NOZZLE PERFORMANCE:**
- #13 @ 40 PSI - 12.4 GPM 53 RADIUS
  - #15 @ 40 PSI - 14.7 GPM 55 RADIUS
- HUNTER ICV/IBV ELECTRIC CONTROL VALVE SIZED AS SHOWN
- HUNTER HQ-44-XX-AW QUICK COUPLER VALVE (OPTIONAL)
- HUNTER IC-1200 SOLID STATE METAL CABINET CONTROLLER
- HUNTER SOLAR-SYNC-SEN ON SITE WEATHER SENSOR
- WATER METER MINIMUM SIZE @ 103 GPM IS 2.0"
- BACKFLOW PREVENTER SIZED TO SYSTEM GPM
- MAINLINE PIPE
- LATERAL PIPE
- SLEEVING
- ⊗ ISOLATION VALVE LINE SIZED
- HUNTER FLOW SENSOR IN LINE SIZED FLOW CLIK TEE "FCT"

### IRRIGATION NOTES

1. SPRINKLER LOCATIONS ARE TO SCALE
2. PIPE LOCATIONS ARE DIAGRAMMATIC
3. ALL SPRINKLERS TO BE INSTALLED ON 1" SCH 80 SWING JOINTS
4. ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS
5. MAINLINE DEPTH TO BE NO LESS THAN 18"
6. LATERAL DEPTH TO BE NO LESS THAN 16"
7. ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
8. LOCATE VALVES/OCVS OUT OF HIGH TRAFFIC AREAS
9. WIRE SPICE CONNECTIONS TO BE WATERPROOF
10. OCV TO BE LOCATED IN 10" VALVE BOX
11. ALL SLEEVES TO BE 2X PIPE RUN THROUGH THEM
12. INSTALL ALL COMPONENTS AS PER LOCAL, STATE, FEDERAL CODES
13. REFER TO HUNTER INSTALLATION DETAILS
14. REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
15. ADD HUNTER "FS" FOR DIRTY WATER VALVE
16. ADD HUNTER "AS" FOR PRESSURE REGULATED VALVE

### VALVE ID GUIDE

STATION NUMBER	ZONE	SIZE	FLOW	PR	DU	SC
A1	1.5"	59	.82"	.69	1.5	1.5
55	1.5"	84	.98"	.79	1.3	1.3
55	1.5"	84	.98"	.79	1.3	1.3
A2	2"	73	.93"	.75	1.4	1.4
A4	1.5"	73	.93"	.75	1.4	1.4
A5	1.5"	59	1.07"	.77	1.5	1.5
A6	1.5"	59	1.07"	.77	1.5	1.5
A8	1.5"	59	1.07"	.77	1.5	1.5
A9	1.5"	59	1.07"	.77	1.5	1.5
A10	2"	103	1.07"	.77	1.5	1.5
A11	2"	103	.54"	.71	1.4	1.4
A12	2"	103	.54"	.71	1.4	1.4

### SYSTEM PERFORMANCE DATA

Hunter Industries offers this data as a general guide for estimating purposes and offers no warranty, express or implied, for the use of this data. The user is responsible for the design of every system and of every site we recommend that a qualified irrigation designer be consulted.



OFFICIAL BASEBALL FIELD  
I-35LP FIVE ROW DESIGN

Hunter Industries  
1940 Diamond Street  
San Marcos, California 92078  
SpecPro Technical Assistance  
800-319-4796  
www.HunterIndustries.com

SHEET  
1 OF 1